



കേരള സർക്കാർ

ലൈഫ് മിഷൻ

Livelihood Inclusion and Financial Empowerment

Navakeralam Karmapadhathi, BSNL Bhavan, 3rd Floor, Uppalam Rd, Statue,
Thiruvananthapuram - 695001, Kerala, Ph: 0471- 2335524, 0471-4014439,
Website : www.lifemission.kerala.gov.in ,E-mail : lifemissionengg@gmail.com


LM/EW/71/TDLCCS-PILOT-EXT work/2020-21

19/10/2023

OFFER NOTICE

The Chief Executive Officer, LIFE MISSION inviting offers from experienced firms for the DESIGN, SUPPLY, INSTALLATION, TESTING AND COMMISSIONING OF WATER TREATMENT PLANT FOR LIFE TOWER APARTMENT AT PUNALUR, KOLLAM INCLUDING 5 YEAR ANNUAL MAINTENANCE.

More details can be had from the office of the, LIFE MISSION KERALA, NAVAKERALAM KARMA PADHATHI, 3rd Floor, BSNL Bhavan, Uppalam Road, Statue, Thiruvananthapuram 695001. Ph No. **0471- 2335524** during working hours. Contact No .9446000210. E-mail: life_missionengg@gmail.com


Chief Executive Officer
LIFE Mission

Encl: Bill of Quantities

Item Rate Boq

Validate

Print

Help

Tender Inviting Authority: Chief Executive Officer, Life Mission Kerala

Name of Work: LIFE MISSION KERALA - ESTIMATE FOR DESIGN, SUPPLY, INSTALLATION, TETSING AND COMMISSIONING OF WATER TRETAMENT PLANT
 PUNALUR MUNICIPALITY, KOLLAM DISTRICT

Contract No:

Name of the Bidder/ Bidding Firm / Company :

PRICE SCHEDULE
 (This BOQ template must not be modified/replaced by the bidder and the same should be uploaded after filling the relevent columns, else the bidder is liable to be rejected for this tender.
 Bidders are allowed to enter the Bidder Name and Values only)

Sl. No.	Item Description	Quantity	Units	BASIC RATE In Figures To be entered by the Bidder Rs. P	TOTAL AMOUNT Without Taxes	TOTAL AMOUNT In Words
NUMBER #	TEXT #	NUMBER #	TEXT #	NUMBER #	NUMBER #	TEXT #
1	1 Design, Supply, Installation, testing and commissioning of water treatment plant (WTP) of 6,000 liters/hour capacity to meet the drinking water norms as prescribed by the Kerala water authority for 44 dwelling unit LIFE apartments at Punalur on TURN KEY basis complete. Parameters of treated drinking water limits : 1. Color - 5 (Unit Hazen) 2. Odour - Agreeable 3. Turbidity - 1 (Unit NTU) 4. pH at 25 °C - 6.5 to 8.5 5. Total alkalinity (as CaCO3) - 200 (mg/L) 6. Total dissolved solids (at 180 °C) - 500 (mg/L) 7. Total hardness (as CaCO3) - 200 (mg/L) 8. Calcium (as Ca) - 75 (mg/L) 9. Magnesium (as Mg) - 30 (mg/L) 10. Chloride (as Cl) - 250 (mg/L) 11. Sulphate (as SO4) - 200 (mg/L) 12. Flouride (As F) - 1 (mg/L) 13. Iron (As Fe) - 1 (mg/L) 14. Nitrate (As NO3) - 45 (mg/L) 15. Total Coliforms/100 ml-Shall not be detected/100 ml 16. E Coli /100 ml -Shall not be detected/100 ml	4	5	13	53	INR Zero Only
1.01	WATER TREATMENT PLANT	1,000	L.S		0.000	INR Zero Only

2		ANNUAL MAINTANCE									
2.01	Maintenance cost for 1st year, including labour, chemicals, media replacements etc, but excluding the cost of electricity and labour cost for operation	1.000	L.S			0.000	INR Zero Only				
2.02	Maintenance cost for 2nd year, including labour, chemicals, media replacements etc, but excluding the cost of electricity and labour cost for operation.	1.000	L.S			0.000	INR Zero Only				
2.03	Maintenance cost for 3rd year, including labour, chemicals, media replacements etc, but excluding the cost of electricity and labour cost for operation.	1.000	L.S			0.000	INR Zero Only				
2.04	Maintenance cost for 4th year, including labour, chemicals, media replacements etc, but excluding the cost of electricity and labour cost for operation.	1.000	L.S			0.000	INR Zero Only				
2.05	Maintenance cost for 5th year, including labour, chemicals, media replacements etc, but excluding the cost of electricity and labour cost for operation.	1.000	L.S			0.000	INR Zero Only				
Total in Figures						0.000	INR Zero Only				
Quoted Rate in Words						INR Zero Only					

d

Handwritten signature
CEO